

TONOPAH PUBLIC UTILITIES

Consumer Confidence Report – 2024

Covering Calendar Year – 2023

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. It is important that customers be aware of the efforts that are continually being made to improve their water systems. To learn more, please attend any of the regularly scheduled meetings. **For more information please contact Robert Herren at 775-482-6336.**

Your water comes from:

Source Name	Source Water Type
WELL 8	Ground Water
WELL 5	Ground Water
WELL 9	Ground Water
WELL 6	Ground Water
WELL 7	Ground Water
WELL 10	Ground Water

We add disinfectant to your water to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) requires states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of our source water. For results of the source water assessment, please contact us.

Message from EPA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some

cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, can be naturally occurring or the result of mining activity

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, may also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system tested a minimum of 5 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presences in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television, or radio.

Water Quality Data

The tables following below list all of the drinking water contaminants that were detected during the 2023 calendar year. The presence of these contaminants does not necessarily indicate that the water poses a health risk. Unless noted, the data presented in this table is from testing done January 1- December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

Maximum Contaminant Level (MCL): the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG’s do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Detects (ND): laboratory analysis indicates that the constituent is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU): nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Testing Results for TONOPAH PUBLIC UTILITIES

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2023				

Lead and Copper	Date	90 TH Percentile	Unit	AL	Sites Over AL	Typical Source
COPPER	2020- 2022	0.048	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
LEAD	2020 - 2022	0.001	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection By-Products	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Typical Source
TTHM	2023	1	ND	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MC LG	Typical Source
ARSENIC	01/3/2023	5.64	5.64-5.64	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
BARIUM	03/09/2022 04/05/2022	.11	0.079- 0.11	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
CHROMIUM	03/09/2022 04/05/2022	.002	.001-.002	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
NITRATE	01/3/2023	7.7	2.2-7.7	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MC LG	Typical Source
COMBINED RADIUM (-226 & -228)	04/04/2023	0.705	0.195 - 0.705	pCi/L	5	0	Erosion of natural deposits
COMBINED URANIUM	07/06/2020	3.33	3.13 3.33	µg/L	30	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	04/04/2023	2.85	1.67 – 2.85	pCi/L	15	0	Decay of natural and man-made deposits
GROSS BETA PARTICLE ACTIVITY	04/04/2023	1.74	1.74 – 1.74	pCi/L	50	0	Decay of natural and man-made deposits
RADON	02/04/2014	379.2	344.8 - 379.2	PCI/L			

Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL	MCLG
CHLORIDE	03/09/2022 04/05/2022	14	13-14	mg/L	400	
MAGNESIUM	03/09/2022 04/05/2022	3.6	3.4-3.6	mg/L	150	
MANGANESE	03/09/2022 04/05/2022	0.001	0.001	mg/L	0.1	
PH	03/09/2022 04/05/2022	7.98	7.98-7.99	PH	8.5	
SODIUM	03/09/2022 04/05/2022	25	22-25	mg/L	200	20
SULFATE	03/09/2022 04/05/2022	33	24-33	mg/L	500	
TDS	03/09/2022 04/05/2022	270	260 - 270	mg/L	1000	

Health Information About Water Quality

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

While your water meets the EPA's standard for Lead, *if present at elevated levels* this contaminant can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. Tonopah Public Utilities had one positive result in January for Total Coliform in 2023 and this was a warning of possible problems. We performed additional sampling that month, and all samples have since shown no further evidence of this biological contaminant.

Violations

During the 2024 calendar year, TONOPAH PUBLIC UTILITIES is required to include an explanation of the violation(s) in the table below and the steps taken to resolve the violation(s) with this report.

Type	Category	Analyte	Compliance Period
VOC	Phase 2/5	1,2,4 Trichlorobenzene	Jan. 1-Dec. 31 2023
<p>Tonopah Public Utilities had a positive sample result from Rye Patch Vault Group 2 while sampling for 1,2,4 Trichlorobenzene which falls in the testing category under VOC's Phase 2 and 5. Tonopah Public Utilities resampled that spot and came back with a negative result on the follow-up sample. Tonopah Public Utilities is required to sample for 1,2,4 Trichlorobenzene one time per year for the next 3 years as long as negative results are achieved. The last round of samples will be taken in Calendar year 2024.</p>			